

ACN: 108 930 089

ABN: 64 108 930 089

Client:	All Used Equipment			Site:	230-232 Welshpool Road		
Date:	02/08/2023	Job#:	34171	Asset No:	C200D2R		

RESIDUAL CURRENT DEVICE CHECKS

RCD No. or Description	mA Rating	CURRENT & TRIP TIME											
		mA Rating x ½				mA Rating x 1				mA Rating x 5			
		0°		180°		0°		180°		0°		180°	
		mA	mS	mA	mS	mA	mS	mA	mS	mA	mS	mA	mS
Earth Leakage	100	50	N/t	50	N/t	100	241	100	232	500	212	500	212


INSULATION TESTING

Description	Volt Grade	Test Volts	Insulation Resistance (Ω)					Phase & Earth Resistance	Termination & Cable No. check	
			R-W	R-B	B-W	RWB-N	RWB-E		Origin	Dest.
			Alternator	415	1000	0.1	0.1		0.1	-
Main switch	415	1000	999M	999M	999M	999M	999M	0.08	Alternator	Main Switch
Outlet	415	1000	999M	999M	999M	999M	999M	0.08	Main switch	Outlet

COMMENTS:

RCD Test Date:	02/08/2023	Next Test Date:	02/08/2023	EWL#:	13100
-----------------------	------------	------------------------	------------	--------------	-------

I certify that all electrical tests were carried out to suit all the requirements of the Electricity (Licensing) Regulations 1991.

Electrician Name:	Billy Hutchinson	Electrician Signature:	
--------------------------	------------------	-------------------------------	---