

Westralian WD Diesel

ACN: 108 930 089
ABN: 64 108 930 089

MOB: 0418 920 85
OFFICE: 08 6363 561

155 Milner Road
Forrestfield WA 6055

PO Box 10
Kalamunda WA 6970

PLEASE PAY BY	AMOUNT	INVOICE DATE
08/08/2023		08/08/2023

TAX INVOICE NO. 74387

All Used Equipment
230-232 Welshpool Road
Welshpool WA 6106

Order No.:
Job No.: 34171
Invoice Terms: COD
ABN:

Work overview:

- Inspect and report faults found on three gensets.
- Load test three gensets.
- Repair electrical faults found across the three gensets.

Faults and issues found:

Cummins Power C150D2R:

- Marechal outlet housing is missing.
- The earth leakage device does not work.
- Fuel level fault on the controller.

Work completed:

Cummins Power C150D2R:

- Replaced the Marechal housing and re-connected the Marechal plug.
- Connected the load bank and load tested the genset.
- Completed the load test data sheet.
- Disconnected the load bank.
- Carried out the electrical testing and completed the electrical test sheet.
- Found the earth leakage device does not work. The customer has advised us to remove the Marechal outlet as it is the only circuit not protected by an RCD.
- Blanked off the Marechal outlet hole and gave the Marechal outlet, housing and cabling to the customer.
- Removed the fuel level fault from the controller programming as requested by the customer.
- Re-fitted all of the cover

PERTH METROPOLITAN AND STATE WIDE

HEAVY DUTY EQUIPMENT

-mining -automotive
-power generation

