



Asset History Report

W/O No	Description	Completed	Down time	Repair time	Dur.	P/M	Job Type	Cost
GE50	Mosa - Lombardini - 8.5 kVA Generator	PLANT						
32187	check fuel leak	4/11/2020	2: 0.000	1.00	1.000		GM	
32186	fit isolators	7/09/2020	1 0.000	0.00	2.000		GM	
30613	OFF HIRE - Inspection	4/11/2020	2: 0.000	1.50	1.500	215	Insp	
29858	250hr Generator Service	20/05/2021	0.000	0.00	2.500	78	PM	
27715	Broken fuel cap	4/04/2020	3: 0.000	0.00	0.000		DA	
25390	No fire extinguisher	11/01/2020	0.500	0.50	0.000		Defect	
23712	2000hr Generator Service	11/01/2020	1.000	1.00	2.500	80	PM	
23149	ON HIRE - Inspection	18/11/2019	0.000	3.50	1.500	136	Insp	
17935	Inspect run up and make good for site	2/04/2019	6: 0.000	0.00	2.000		GM	
16276	ON HIRE - General Condition Report - Inspection (GCR)	14/02/2019	2.000	2.00	1.500	136	Insp	
12845	250hr Generator Service	17/09/2019	0.000	4.00	2.500	78	PM	
6000	fit battery and start check levels	6/04/2018	1 0.000	0.00	2.670			
5917	General Condition Report - On Hire / Off Hire	9/04/2018	1 1.000	1.00	1.500	136	Insp	
13		Total	4.50	14.50				