

ACN: 108 930 089

ABN: 64 108 930 089

Client:	All Used Equipment			Site:	230-232 Welshpool Road		
Date:	02/08/2023	Job#:	34171	Asset No:	Upon LC150C		

RESIDUAL CURRENT DEVICE CHECKS

RCD No. or Description	mA Rating	CURRENT & TRIP TIME											
		mA Rating x ½				mA Rating x 1				mA Rating x 5			
		0°		180°		0°		180°		0°		180°	
		mA	mS	mA	mS	mA	mS	mA	mS	mA	mS	mA	mS
Earth leakage	100	50	N/t	50	N/t	100	212	100	212	500	181	500	186
Outlet 1	30	15	N/t	15	N/t	30	21	30	21	150	9	150	9


INSULATION TESTING

Description	Volt Grade	Test Volts	Insulation Resistance (Ω)					Phase & Earth Resistance	Termination & Cable No. check	
			R-W	R-B	B-W	RWB-N	RWB-E		Origin	Dest.
			Alternator	415	1000	0.1	0.1		0.1	-
Main Switch	415	1000	999M	999M	999M	999M	999M	0.09	Alternator	Main switch
Marechal outlet	415	1000	999M	999M	999M	999M	999M	0.09	Main switch	Marechal outlet
Outlet 1	240	500	999M	999M	999M	999M	999M	0.09	Main switch	Outlet 1

COMMENTS:

RCD Test Date:	02/08/2023	Next Test Date:	02/08/2023	EWL#:	13100
-----------------------	------------	------------------------	------------	--------------	-------

I certify that all electrical tests were carried out to suit all the requirements of the Electricity (Licensing) Regulations 1991.

Electrician Name:	Billy Hutchinson	Electrician Signature:	
--------------------------	------------------	-------------------------------	---